1 Organizational Aspects

Project:	**Building Automation System**
Subproject:	**Groupoffices-Thermal-Light-Security-Control**
Documenttype:	**Problemdescription**
Documentname:	**team2-problemdescription**
Responsible:	**SFB501-D1**
User:	**Team2**
Description:	System for controlling heat supply, ventilation, lighting and shading to guaranty comfort and energy saving, and in addition simple safety and security.

Version#	Date	Creators	Remarks
v1	3.4.95	Zimmermann	
v1.1	18.4.95	Queins	
v2	24.5.95	Queins	
v2.1	11.6.95	Zimmermann	Small changes and additions
v3	18.12.95	Dellen/Schütze	Unterteilung der Anforderungen/ Funktionalität in Bedingung-stypen Anpassung der Sensoren/Aktu-ratoren an Testraum
team2	18.1.95	Dellen	Einschränkung für Team2 -Lüftung -Temperatur -Safety KEINE BLINDS

2 Problem

[1] Three time periods are distinguished: *off-time* = no occupancy expected; *stand-by time* = occupancy expected but room not occupied; *comfort time* = room occupied

2.1 Informal Description (Statement of Ideas and Need)

[2] The total *system* is composed of a *standard room within an university building (namely room 32/418 of Univ. of Kaiserslautern)*with *installation* (including *sensors* and *actuators*), *users*, and the *control system*. The control system is composed of hardware and software components. The building is influenced by its *environment*, mainly the *weather*.

[3] *University buildings* can be of different type, depending on usage. The building and usage will differ greatly between administration, lecture halls and the different departments. Here we will assume a typical *computer science department building* The controlled standard room is assumed to be a typical subunit of a department occupied by the members of the research group of one professor.

[4] The problem is the delivery of a new control system that satisfies user needs of one standard room . The control system shall be designed such that it can be easily changed and expanded. In the following tables, the general needs are listed.

2.1.1 Group Member Needs

[5] Group members are all members of the research group that work in the space of the group for longer periods, as for example:

[6] *Professor, scientists, secretaries (as users), technicians, programmers*, and *students*.

[7] The actual user is one (or more) person, who actually occupies the room.

Table 1: Group member needs

#	Short Name	Description
G1	comfort temperature	The comfort temperature shall be maintained during preset comfort times or reached as fast as possible, when the room is occupied for a longer time period. This state is called “occupied” and is explained in the state chart below. This requirement shall be fulfilled during the heating period, and, if possible, also during the rest of the year. During the states “empty” and “entered” appropriate actions have to be taken.
G2	room ventilation	*Ventilation* in the room has to be in accordance DIN 1946 T.2, according to usage (duration and number of persons in the room).
G5	safety against weather	In the case of hazardous conditions the windows have to be closed to secure the member’s and group’s possessions.
G6	control comfort	All functions shall be controllable by simple keys or a control panel near the main door
G7	input consistency	The user inputs shall be checked in order to prevent unreasonable behavior of the system.

<- CL 7

[8] We distinguish three time spans for detecting occupancy. If a person is in a room shorter than T1 minutes, the control system does not try to reach the comfort temperature (state “empty”, stand-by or off-time temperature, depending on the time period). If the person occupies the room for a time longer than T1, the system goes into the state “entered” and starts to reach the comfort temperature. If the person leaves the room before T2 minutes, the system returns to the previous temperature. If the person occupies the room longer than T2, the system enters the state “occupied”, where the comfort temperature should be held, until this person leaves the room for at least T3 minutes. Different settings for (T1, T2, T3) may exist for each room, depending on the expected usage (day, night, vacation etc.). **<- CL 7**



Default Values
(set by the custodians)

T1: 1 min.
T2: 5 min.
T3: 30 min.

2.1.2 Custodian Needs

Table 2: Custodian needs

#	Short Name	Description
C10	Freezing prevention	Freezing of water pipes and radiators has to be prevented by all means.

2.1.3 Owner Needs

[9] The owner is in the case of a university the department that is responsible to pay for energy consumption, repairs, maintenance etc.

Table 3: Owner needs

#	Short Name	Description
O1	heating	Minimum heating energy consumption.
O2	ventilation	Sufficient ventilation to prevent damage through humidity.
O5	safety	Avoidance of damage to windows in regard to weather conditions.
O9	off-time	Minimum energy consumption during off-time.

2.2 Existing System

[10] Currently the *room temperature* is maintained during the heating period with a hot water system and *radiators* with thermostat control valves in each room. Thermostats are operated by group members. Central control is maintained by adjusting the input water temperature.

[11] *windows* can only be operated manually.

[12] Safety is only supported at night by security guard.

[13] **Disadvantages** of the current system:

[14] Energy waste by heating of unused rooms, imprecise control through thermostats, hot water generation and distribution loss higher than necessary due to worst case input temperature.

[15] windows, inventory can be damaged by weather due to lack of problem reporting and automatic problem solution if possible.

[16] Ventilation cannot be controlled properly and cannot be used to save energy by minimal ventilation periods during heating or to cool rooms during the night to reduce overheating during summer.

[17] Maintenance bookkeeping is time consuming for custodians and service technicians.

2.3 Proposed System Functionality

[18] Need# lists one or more requirements from chapter 2.1 that can be solved by the proposed function.

Table 4: Functions

F #	Need#	Short Desc.	Description
F1	G1, O1	room comfort control	Control the measured room temperature such that the comfort temperature is maintained within given deviations during the comfort time or occupied state and heating period. Set radiator control valves Outside of the heating periods comfort temperature is maintained as good as possible by using the heat storage capacity of the building.
F2	C10, O1,3, O9	room stand-by control	Control room temperature during stand-by-time such that a user required heat-up can be guaranteed under normal conditions and energy loss is minimized. The temperature has to be greater than 0^{o} C
F3	G1, O1	room heat-up control	Determine heat-up time and start heating up a room such that comfort temperature is reached at begin of comfort times in a moderate time interval and energy consumption is minimized. Take room environment temperatures including heat storage capacity into account.
F4	Se1	stand-by time determination	Determine the period of the current and next stand-by time, taking working habits, holidays, vacation, off-site-times, and presence of a person.
F5	G1	radiation load control	use storage capacity of building.
F7	G1, O1	temperature control via ventilation	Use outdoor temperatures and heat storage capacity to control room temperature during all times either to save energy or to prevent room temperatures higher than comfort temperature via ventilation.
F8	G2, O2	good air control	Ahead and during comfort times control ventilation to guarantee sufficient fresh air depending on number and time of persons present.
F14	G5, O5	window safety control	Close automatic windows or warn nearest person in case of possible wind or water damage because of open windows or attempts to open windows.
F15	?	occupancy detection	Try to determine occupancy of room, including number of persons, from infrared detector, door contact history, and keyboard activity.
F21	G6	user interface	Provide comfortable user interface

Table 4: Functions

F #	Need#	Short Desc.	Description
F22	G7,	consistency check	Check all input data for consistency.
F24	O6	reporting	Store selected events in database and provide reports as necessary.
F26	O1-3, O9	off-time	Determine the off-time settings in respect of minimum energy consumption.

3 Control System Environment Characteristics

3.1 Problem Context

3.1.1 Interference

19 The system is part of a hierarchy of control systems. The next higher system coordinates the actual control system (ACS) and other similiar systems (OCS). The ACS do not have the permission to control functions of OCS. It only may pass messages to get informations about sensor values or to make proposals to the OCS. **<- CL 9**

3.1.2 Safety and Legal Aspects

20 All hardware connections have to be made according to DIN standards.

21 No hazardous conditions for persons, inventory, or building is allowed.

22 Otherwise no legal restrictions apply because the system is part of an experiment.

3.2 System Context

3.2.1 Building Section

[23] The room is surrounded by two rooms and a hallway, each with doors and has three window sections.

[24] All windows have a lower and an upper *sash*. The lower sash can be fully opened. The upper sash can only be tilted.

[25] All windows have blinds.

3.2.2 Installation

[26] Each room is equipped with
one or more motion detector, so that the room is fully covered,
three air temperatur sensors in different positions,
a ceiling light detector,
a humidity detector
a room siren.

[27] Each window section of a room is equipped with:
one radiator with a radiator control valve,
an input and an output water temperatur sensor
as well as a mean radiator temperature sensor,
an upper sash opener,
a combined blind lifter/rotator
a sash-closed, sash-locked, and a sash-opened contact for the lower sash,
a sash-closed contact for the upper sash,
a ceiling light fixture that can be dimmed.

[28] Each door is equipped with
a door-closed, a door-open, and a lock-closed contact.

[29] All rooms have a control unit to adjust the individual comfort values of the actual user. The control unit is composed of a little control panel one-line display and a keyboard. At the control panel the five last messages of the system (errors, warnings, ...) can be displayed. All the functions of the control unit can be also accessed through an user interface which can be displayed at each terminal. Outside rain, temperature, humidity, *wind speed* and *wind direction* are measured.

3.2.3 Sensors

[30] This section describes the real physical sensors including converters if necessary.

[31] Ananlog sensors have typically an exponential time response. Reaction time is the time from a change of the sensed property to the time when the sensor has reached 90% of the change, excluding conversion time. Conversion time is the time to convert the analog to a digital value, that can be accessed by the control system.

[32] NC means “normally closed”. Closed is coded as 1, open as 0.

Table 5:

Name	Abbrev.	Type	Resolution	Range	Reaction / Conversion Time	Description
door-closed contact	dcc	NC-contact		0, 1	10 ms	It is placed above the door and is 1, if the door is fully closed.
door-open contact	doc	NC-contact		0, 1	10 ms	It is placed above the door and is 0, if it is opened for at least 30 degree.
door-lock contact	dlc	NC-contact		0, 1	10 ms	It is placed in the door frame and is 1, if the lock is closed with a key
motion detector	imd	passiv infrared motion detector		0, 1	1 s	1 means a person is moving, even very slow, in the range of the detector.
room humdity sensor	rhs	analog, capacitance	1 %	10-90 %	300 s / 1s	measures relative humidity
sash-closed contact	scc	NC-contact		0, 1	10 ms	It is placed above the window sash and is 1, if the window is fully closed.
sash-lock contact	slc	NC-contact		0, 1	10 ms	It is placed in the lock of the sash and is one if the sash is manually locked.
sash-open contact	soc	NC-contact		0, 1	10 ms	It is placed at the side of the window and is 0, if it is opened for at least 30 degree.
water temperature sensor	wts	analog PWM contact thermometer	0.1 C	0 - 100 C	10 s / 60s	Connected to the incoming and outgoing water pipes near the radiator.
room temperature sensor	rts	analog PWM air thermometer	0.1 C	-40 - +70 C	60 s / 60s	It measures the room temperature at three points of the room.

Table 5:

Name	Abbrev.	Type	Resolution	Range	Reaction / Conversion Time	Description
wind speed sensor	wss	analog FM anemometer	1 ms^{-1}	0 - 56 ms^{-1}	10 s / 10 s	Mounted on the roof of the building
wind direction sensor	wds	analog	1	0 - 359	10s / 1 s	Mounted on the roof of the building
outdoor temperature sensor	ots	analog PWM air thermometer	0.1 C	-40 - +60 C	120 s / 60 s	Mounted in the shadow of the building
outdoor humidity sensor	ohs	analog PWM	1%	10 - 90%	300 s / 30 s	Mounted in the shadow of the building
outdoor rain sensor	ors	quasi-analog	1mm	1-100 mm/h	sev. min.	counts the mm of rain since last reset (every 24h).

3.2.4 Actuators

[33] One can not expect that actuators are completely linear over a longer period of time. Position of actuators must therefore be controlled by using positions known for sure (e.g. ‘completely closed’) as reference.

[34] 3-point means three control states: forward, stop, backward. The actuator moves as long as the forward or backward state is on. Thus the position can be controlled by the length of time in the two states, depending on the previous position. End-contacts are provided to stop the motion automatically.

Table 6: Actuators

Name	Abbrev.	Type	Range	Control	Reaction Time	Description
blind lifter/ rotator		motor	lift: 0..100 % rotate: 0..180 a	3-point	lift:120 s rotate: 15s	Lets down blind between 0% (up) and 100% (down). Rotates blind blades between 0 and 180 degrees. At x degrees light can enter from an angle x degree from vertical. At 0 and 180 the blind is totally closed. DOWN command sets the angle to 0 degrees and starts moving down the blinds afterwards. UP command sets the angle to 180 and starts moving up afterwards. All settings are reached by useful combinations of up- and down-commands.
radiator-valve		radiator control valve	0 - 100%	3-point	420 s	Electrically controlled to open continuously between 0 and 100%.
window-opener		motor	0.. 100%	3-point	25 s	Tilts sash between 0 and 100%. MOVEMENT NOT LINEAR.

4 Dictionary of Terms

35 Reference points to entries in the document “Lexikon”

Table 7: Dictionary of keywords of the application domain

keyword	reference	description	german
actual user		current user of a room	aktueller Benutzer
actuator		device that can be controlled by control system	Aktuator
comfort temperature	!	expected temperature during normal usage of a room	
comfort time		time period in which full room climate comfort is expected	Benutzungszeit
computer lab		Room with many terminals, workstations, open to all group members and temporarily to students of a class	Terminalraum
computer science department building		building with typically offices, computer labs, peripheral rooms etc.	Informatikgebäude
contact		electrical or magnetic gadget to determine the state of a door, window etc.	Kontakt
control panel		Small panel at the wall with a keyboard, LEDs for important states, and a simple display for textual messages	
control system		Hard- and software system that controls indoor climate, lighting, safety and security	Kontrollsystem
custodian		Person responsible for running a building on a daily bases	Hausmeister
door	door		Tür
environment		surrounding of section of the building, indoor and outdoor	Umgebung
group member		Persons in research group of one professor	Gruppenmitglieder
hallway	hallway	part of a building between several rooms to connect each of them	Flur
heating period	!	period of the year in which central heat is supplied	Heizperiode
heat-up time	!	time in which comfort temperature is reached	Aufheizzeit

Table 7: Dictionary of keywords of the application domain

keyword	reference	description	german
humidity	air		Luft-feuchtigkeit
installation	installa-tion	Equipment belonging to the building and that can be operated, as e.g. radiators, win-dows openers, light fixtures	Installation
off-time		time in which no usage is expected	
owner		Head of university	Präsident
professor		head of a research group	Professor
programmers		people who realize implementations	Programmierer
radiator	radiator	hot water radiator	Heizkörper
radiator con-trol valve	! radia-tor con-trol valve		Heizkörper-ventil
rain sensor		closes contact if wet	Regenfühler
room	room		Raum
room tempera-ture	room cli-mate	Temperature of the air	Raumtempera-tur
sash	sash	flexible part of a window, door etc.	Flügel
secretary			Sekretärin
sensor		device that can sense state of the building, users or environment	Sensor
service techni-cian		Person responsible for maintenance and repair of controlled system	Servicetechni-ker
solar radiation	solar radiation	Irradiance, measured in w/m^2	Sonnenein-strahlung
stand-by time		time in which an inhabitant is expected in a room	
storage room	storage room	Room for storage of files, books, manuals etc., access for all group members	Lagerraum
students			Studenten
system			System
technician			Techniker

Table 7: Dictionary of keywords of the application domain

keyword	reference	description	german
university building		Building in a university	Universitäts-gebäude
user			Benutzer
ventilation	!	According to DIN 1946T.2 is the minimal fresh air input per person in an office or lecture hall 30 m^3h^{-1}	Belüftung
weather		outdoor temperature, wind, radiation, humidity	Wetter
wind direction	wind	Direction from which the wind is blowing. North is 0 , east is 90 .	Windrichtung
window	window		Fenster
wind speed	wind		Windge-schwindigkeit

5 Change Log

Problem # 1, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

No description about the service technicians.

Solution:

Give a short description.

Change Date & New Version: 24.5.95, v2

Problem # 2, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

No assumption about en- or disabling the telephone use in case of an alarm.

Solution:

Delete this sentence.

Change Date & New Version: 24. 5. 95, v2

Problem # 3, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

Inhomogenous conception of “actual user”.

Solution:

Short definition of the meaning.

Change Date & New Version: 24.5.95, v2

Problem # 4, Detection Date & Version: 23.5.95

Reason:

Description:

No assumption about the control of the system

Solution:

Give an overview of the several kinds of control units.

Change Date & New Version: 24.5.95, v2

Problem # 5, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

Who is responsible for the public rooms like stairways, ...

Solution:

The custodian has to fulfill these tasks.

Change Date & New Version: 24.5.95, v2

Problem # 6, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

The needs of the secretaries should be listed in a separate manner. This is necessary because of the special interface, the secretaries need to fullfil this task.

Solution:

Create a new table secretary needs.

Change Date & New Version: 29.5.95, v2

Problem # 7, Detection Date & Version: 23.5.95, v1.2

Reason:

Description:

Inhomogenous conception of the time when the comfort temperature should be reached or the stand-by temperature is sufficient.

Solution:

Give an explanation by a state chart.

Change Date & New Version: 30.5.95, v2

Problem # 8, Detection Date & Version: 23.5.95

Reason:

Description:

There is no description who may override the settings of another.

Solution:

Build a hierarchy to explain it.

Change Date & New Version: 30.5.95, v2

Problem # 9, Detection Date & Version: 23.5.95

Reason:

Description:

No assumption about the interference with other control systems.

Solution:

Arrange the system in a hierarchy of control systems.

Change Date & New Version: 31.5.95, v2

Problem # 10, Detection Date & Version: 23.5.95, v1.1

Reason:

Description:

Discussion of the security alarm system.

Solution:

Give a more precise description of the desired functionality.

Change Date & New Version: 1.6.95, v2